



Checklist for a Paint Spray Booth Submittal

To qualify for a paint spray booth release, an applicant must provide a complete application form (ACDR) indicating the paint spray booth scope of work, and a complete set of drawings and support information demonstrating compliance with all applicable building laws and fire safety laws. Minimum submittal requirements for the paint spray booth scope include the following, as applicable:

- A dimensioned floor plan showing the location of building exits and the location of the paint spray booth within the building;
- Plans and sections showing how the paint spray booth is vented to the exterior of the building;
- Manufacturer specification sheets of the paint spray booth;
- Fire extinguishing system drawings demonstrating compliance with all applicable building laws and fire safety laws, including the following:
 - Plans drawn to scale or suitably dimensioned, prepared by qualified persons trained in the design and application of these systems;
 - Detailed information to allow evaluation of the hazard or hazards, and to evaluate the effectiveness of the system;
 - Hazard information, including materials involved, their location and arrangement, and the exposure to the hazard;
 - System details and calculations including:
 - Amount of chemical;
 - Size, length and arrangement of connected piping, or piping and hose;
 - Description and location of nozzles to determine adequacy of the system;
 - Flow rates of nozzles in engineered systems;
 - Information pertaining to the location and function of detection devices, operating devices, auxiliary equipment and electrical circuitry;
 - Sufficient information to properly identify the apparatus and devices used;

- Any additional information that may be necessary to illustrate design intent and demonstrate full compliance with the applicable building and fire safety laws and the rules of the commission;
- No plans may be labeled “Preliminary,” “Not for Construction,” “For Reference Only,” “Future,” “Optional” or the like. They are unacceptable for plan review purposes.